

BHUTAN POWER SYSTEM OPERATOR LOAD-GENERATION BALANCE REPORT

Maximum Load/Demand till Date

| | |
|---------------|--------------------------|
| Date: | September 4, 2020 |
| Hours: | 19:00 Hours |

| Date | Time | Load(MW) |
|-----------|----------|----------|
| 27-Dec-18 | 18:18hrs | 399.35MW |

| Sl. No. | Hydropower Plant | Unit | MW | Name of Feeders | Load (MW) | Sign | Remarks |
|---------|------------------|--------------|---------------|--|-----------|---------------|----------------------------|
| 1 | 1020MW THP | Unit- I | 186.86 | 400kV THP - Siliguri Fdr- I | 220.13 | + | |
| | | Unit- II | 189.41 | 400kV THP - Siliguri Fdr- II | 218.64 | + | |
| | | Unit- III | 140.80 | 400kV THP - Siliguri Fdr- IV | 214.00 | + | |
| | | Unit- IV | 141.20 | 400kV THP - Malbase Fdr- III | 277.75 | + | |
| | | Unit- V | 148.29 | 400kV Malbase - Siliguri | 194.31 | + | |
| | | Unit- VI | 139.79 | - | - | - | |
| | | Total | 946.35 | Error at Station/Auxiliary Consumption/Losses | | 1.673% | |
| 2 | 720MW MHP | Unit-I | 135.15 | 400kV MHP - Jigmeling Fdr - I | 185.81 | + | 400kV MHP-JLG II Breakdown |
| | | Unit-II | 140.14 | 400kV MHP - Jigmeling Fdr - II | 0.00 | + | |
| | | Unit-III | 135.71 | 400kV MHP - Jigmeling Fdr - III | 192.00 | + | |
| | | Unit-IV | 160.58 | 400kV MHP - Jigmeling Fdr - IV | 192.00 | + | |
| | | - | - | 200MVA, 400/132kV ICT | | | |
| | | - | - | (Local Load) | | | |
| | | Total | 571.58 | Error at Station/Auxiliary Consumption/Losses | | 0.310% | |
| 3 | 336MW CHP | Unit- I | 91.17 | 220kV CHP - Birpara Fdr- I | 119.35 | + | |
| | | Unit- II | 91.53 | 220kV CHP - Birpara Fdr- II | 119.35 | + | |
| | | Unit- III | 91.24 | 220kV CHP - Malbase Fdr- III | 128.06 | + | |
| | | Unit- IV | 91.78 | 220kV CHP - Semtokha Fdr- IV | -15.09 | - | |
| | | - | - | 220kV Malbase - Birpara Fdr. | 98.85 | + | |
| | | - | - | 66kV CHP - Chumdo Fdr. | 5.98 | + | |
| | | - | - | 66kV CHP - Gedu Fdr. | 5.77 | + | |
| | | - | - | 3x3MVA, 66/11kV TFR | 1.70 | + | |
| | | Total | 365.72 | Error at Station/Auxiliary Consumption/Losses | | 0.164% | |
| 4 | 24MW BHP (U/S) | Unit- I | 11.68 | 220kV BHP - Semtokha Fdr. | 43.80 | + | |
| | | Unit- II | 11.68 | 66kV BHP - Lobeysa Fdr. | 17.25 | + | |
| | | Total | 23.36 | 220kV BHP - Tsirang Fdr. | 2.19 | - | |
| | 40MW BHP (L/S) | Unit- I | 20.11 | 5MVA, 66/11kV TFR | 0.58 | + | |
| | | Unit- II | 20.43 | 30MVA ICT, 220/66kV | | | |
| | | Total | 40.54 | Error at Station/Auxiliary Consumption/Losses | | 0.125% | |
| 5 | 126MW DHPC | Unit-I | 45.32 | 220kV DHPC - Tsirang Fdr. | 88.21 | + | |
| | | Unit-II | 45.34 | 220kV Jigmeling - Dagapela Fdr. | 2.30 | + | |
| | | - | - | 5MVA, 220/33kV TFR | | | |
| | | Total | 90.66 | Error at Station/Auxiliary Consumption/Losses | | 2.702% | |
| 6 | 60MW KHP | Unit- I | 16.50 | 132kV KHP - Nangkhon Fdr- I | 37.04 | + | |
| | | Unit-II | 16.50 | 132kV KHP - Kilihar Fdr- II | 27.11 | + | |
| | | Unit- III | 16.50 | 5MVA, 132/11kV TFR | 0.30 | + | |
| | | Unit- IV | 16.50 | 132kV Gelephu - Salakati Fdr. | 42.48 | + | |
| | | - | - | 132kV Motanga - Rangia Fdr. | 53.00 | + | |
| | | - | - | 220kV Tsirang - Jigmeling | 90.23 | + | |
| | | Total | 66.00 | Error at Station/Auxiliary Consumption/Losses | | 2.348% | |

Note: Generation-Load Summary for September 04, 2020 at 19:00hrs.

| Sl. No | Region | Total Generation (MW) | Total Load [Generation - Export (MW)] | Total Load [Feeder Summation (MW)] | Total Export/Import (MW) | Load Balance (MW) |
|--------|--------------|-----------------------|---------------------------------------|------------------------------------|--------------------------|-------------------|
| 1 | Western Grid | 1,466.63 | 191.77 | 175.11 | 1,184.63 | 16.66 |
| 2 | Eastern Grid | 637.58 | 62.52 | 59.20 | 665.29 | 3.32 |
| | Total | 2,104.21 | 254.29 | 234.31 | 1,849.92 | 19.98 |

Note: Generation-Load Summary for September 04, 2019 at 19:00hrs.

| Sl. No | Region | Total Generation (MW) | Total Load [Generation - Export (MW)] | Total Load [Feeder Summation (MW)] | Total Export/Import (MW) | Load Balance (MW) |
|--------|--------------|-----------------------|---------------------------------------|------------------------------------|--------------------------|-------------------|
| 1 | Western Grid | 1,511.99 | 264.47 | 246.10 | 1167.75 | 18.37 |
| 2 | Eastern Grid | 638.75 | 75.41 | 65.83 | 643.11 | 9.58 |
| | Total | 2,150.74 | 339.88 | 311.93 | 1,810.86 | 27.95 |

NOTES: KHP,MHP load collected from site

- The Instantaneous load balance is calculated as (Total generation - (Total export-Import) - Total domestic load) do not tend towards zero. This could be due to the following reasons:
 - Not all the meters are digital and nor are all the meter at all locations can be read at same time (say 9:00hrs) due to many meter to be read manually.
 - The clocks of all the locations are not synchronized.
- This report is generated to give an idea of the generation & load flow for the system at a particular instant.

BHUTAN POWER SYSTEM OPERATOR LOAD-GENERATION BALANCE REPORT

Maximum Load/Demand till Date

| | |
|--------|-------------------|
| Date: | September 5, 2020 |
| Hours: | 09:00 Hours |

| Date | Time | Load(MW) |
|-----------|----------|----------|
| 27-Dec-18 | 18:18hrs | 399.35MW |

| Sl. No. | Hydropower Plant | Unit | MW | Name of Feeders | Load (MW) | Sign | Remarks |
|---------|------------------|--------------|-----------------|--|----------------|------|-----------------------------|
| 1 | 1020MW THP | Unit- I | 187.48 | 400kV THP - Siliguri Fdr- I | 238.86 | + | |
| | | Unit- II | 147.87 | 400kV THP - Siliguri Fdr- II | 237.46 | + | |
| | | Unit- III | 170.52 | 400kV THP - Siliguri Fdr- IV | 232.54 | + | |
| | | Unit- IV | 170.09 | 400kV THP - Malbase Fdr- III | 289.29 | + | |
| | | Unit- V | 168.26 | 400kV Malbase - Siliguri | 212.64 | + | |
| | | Unit- VI | 168.25 | - | - | - | |
| | | Total | 1,012.47 | Error at Station/Auxiliary Consumption/Losses | 1.414% | | |
| 2 | 720MW MHP | Unit-I | 197.73 | 400kV MHP - Jigmeling Fdr - I | 251.33 | + | 400kV MHP-JLG II Breakdown. |
| | | Unit-II | 196.89 | 400kV MHP - Jigmeling Fdr - II | 0.00 | | |
| | | Unit-III | 170.76 | 400kV MHP - Jigmeling Fdr - III | 260.25 | + | |
| | | Unit-IV | 190.27 | 400kV MHP - Jigmeling Fdr - IV | 260.33 | + | |
| | | - | - | 200MVA, 400/132kV ICT | | | |
| | | - | - | (Local Load) | | | |
| | | Total | 755.65 | Error at Station/Auxiliary Consumption/Losses | -2.152% | | |
| 3 | 336MW CHP | Unit- I | 0.00 | 220kV CHP - Birpara Fdr- I | 145.47 | + | Unit I under shutdown |
| | | Unit- II | 87.52 | 220kV CHP - Birpara Fdr- II | 0.00 | + | |
| | | Unit- III | 91.85 | 220kV CHP - Malbase Fdr- III | 157.44 | + | |
| | | Unit- IV | 88.61 | 220kV CHP - Semtokha Fdr- IV | -42.14 | - | |
| | | - | - | 220kV Malbase - Birpara Fdr. | 110.79 | + | |
| | | - | - | 66kV CHP - Chumdo Fdr. | 0.70 | + | |
| | | - | - | 66kV CHP - Gedu Fdr. | 5.09 | + | |
| | | - | - | 3x3MVA, 66/11kV TFR | 0.75 | + | |
| | | Total | 267.98 | Error at Station/Auxiliary Consumption/Losses | 0.250% | | |
| 4 | 24MW BHP (U/S) | Unit- I | 11.86 | 220kV BHP - Semtokha Fdr. | 60.05 | + | |
| | | Unit- II | 11.86 | 66kV BHP - Lobeysa Fdr. | 15.28 | + | |
| | | Total | 23.72 | 220kV BHP - Tsirang Fdr. | -10.62 | - | |
| | 40MW BHP (L/S) | Unit- I | 20.47 | 5MVA, 66/11kV TFR | 0.43 | + | |
| | | Unit- II | 20.75 | 30MVA ICT, 220/66kV | | | |
| | | Total | 41.22 | Error at Station/Auxiliary Consumption/Losses | -0.485% | | |
| 5 | 126MW DHPC | Unit-I | 51.33 | 220kV DHPC - Tsirang Fdr. | 102.05 | + | |
| | | Unit-II | 51.30 | 220kV Jigmeling - Dagapela Fdr. | 1.40 | + | |
| | | - | - | 5MVA, 220/33kV TFR | | | |
| | | Total | 102.63 | Error at Station/Auxiliary Consumption/Losses | 0.565% | | |
| 6 | 60MW KHP | Unit- I | 16.50 | 132kV KHP - Nangkhon Fdr- I | 41.84 | + | |
| | | Unit-II | 16.50 | 132kV KHP - Kilikhar Fdr- II | 22.88 | + | |
| | | Unit- III | 16.50 | 5MVA, 132/11kV TFR | 0.30 | + | |
| | | Unit- IV | 16.50 | 132kV Gelephu - Salakati Fdr. | 47.77 | + | |
| | | - | - | 132kV Motanga - Rangia Fdr. | 42.32 | + | |
| | | - | - | 220kV Tsirang - Jigmeling | 88.60 | + | |
| | | Total | 66.00 | Error at Station/Auxiliary Consumption/Losses | 1.485% | | |

Note: Generation-Load summary for September 05, 2020 at 09:00hrs.

| Sl. No | Region | Total Generation (MW) | Total Load [Generation - Export (MW)] | Total Load [Feeder Summation (MW)] | Total Export/Import (MW) | Load Balance (MW) |
|--------|--------------|-----------------------|---------------------------------------|------------------------------------|--------------------------|-------------------|
| 1 | Western Grid | 1,448.02 | 181.66 | 167.69 | 1,177.76 | 13.97 |
| 2 | Eastern Grid | 821.65 | 48.25 | 63.53 | 862.00 | -15.28 |
| | Total | 2,269.67 | 229.91 | 231.22 | 2,039.76 | -1.31 |

Note: Generation-Load Summary for September 05, 2019 at 09:00hrs

| Sl. No | Region | Total Generation (MW) | Total Load [Generation - Export (MW)] | Total Load [Feeder Summation (MW)] | Total Export/Import (MW) | Load Balance (MW) |
|--------|--------------|-----------------------|---------------------------------------|------------------------------------|--------------------------|-------------------|
| 1 | Western Grid | 1524.41 | 232.89 | 216.75 | 1,223.63 | 16.14 |
| 2 | Eastern Grid | 638.34 | 53.40 | 57.91 | 652.83 | -4.51 |
| | Total | 2,162.75 | 286.29 | 274.66 | 1,876.46 | 11.63 |

NOTES: KHP,MHP load collected from site.

- The Instantaneous load balance is calculated as (Total generation - (Total export-Import) - Total domestic load) do not tend towards zero. This could be due to the following reasons:
 - Not all the meters are digital and nor are all the meter at all locations can be read at same time (say 9:00hrs) due to many meter to be read manually.
 - The clocks of all the locations are not synchronized.
- This report is generated to give an idea of the generation & load flow for the system at a particular instant.